



污水化验2025年月平均报表

	COD _{cr} (mg/L)		BOD ₅ (mg/L)		SS (mg/L)		PH (/)		TN (mg/L)		NH ₃ -N (mg/L)		TP (mg/L)	
	进水	出水	进水	出水	进水	出水	进水	出水	进水	出水	进水	出水	进水	出水
1	263	19	121	3.4	126	7	6.98	6.89	43.9	7.58	40.8	0.571	3.90	0.19
2	263	18	119	3.4	122	7	6.97	6.91	43.9	7.20	40.8	0.676	3.94	0.18
3	257	22	109	3.7	118	6	6.95	6.91	39.4	5.01	35.9	0.768	3.69	0.14
4	241	19	107	3.6	118	6	7.18	7.11	41.8	6.22	37.9	0.400	4.23	0.22
5	213	21	95.1	3.4	109	6	7.11	7.05	39.7	6.16	34.9	0.473	4.40	0.21
6	186	17	81.7	3.4	93	6	7.13	7.01	30.2	6.64	25.5	0.370	3.33	0.22
7	228	21	103	3.5	113	7	7.12	7.13	33.5	7.15	28.7	0.354	4.51	0.22
8	188	17	85.7	3.3	101	7	7.10	7.04	27.2	6.04	24.1	0.270	3.00	0.18
9	186	17	84.9	3.4	101	6	7.18	7.17	29.9	6.50	27.2	0.180	3.48	0.20
10	178	16	81.1	3.1	95	6	7.26	7.21	31.4	6.95	28.5	0.611	4.20	0.17
11	245	19	113	3.6	122	7	7.30	7.15	35.0	7.28	32.3	0.586	4.09	0.19
12	279	16	123	3.6	130	6	7.1	7.0	41.9	6.72	37.1	0.663	4.78	0.14
平均值	227	19	102	3.5	112	6	7.1	7.0	36.5	6.62	32.8	0.494	3.96	0.19





污水化验2025年月平均报表

月份	COD _{cr} (mg/L)		BOD ₅ (mg/L)		SS (mg/L)		PH		TN (mg/L)		NH ₃ -N (mg/L)		TP (mg/L)	
	进水	出水	进水	出水	进水	出水	进水	出水	进水	出水	进水	出水	进水	出水
1	248	17	96.4	3.6	106	6	7.41	7.37	34.8	9.17	27.5	0.364	3.43	0.15
2	247	20	102	3.5	121	7	7.50	7.36	40.7	11.2	31.1	0.646	4.04	0.22
3	270	18	120	3.6	133	7	7.41	7.29	45.0	11.0	29.1	0.746	5.08	0.24
4	291	19	112	3.1	141	7	7.31	7.19	44.0	10.1	30.8	0.270	4.84	0.26
5	260	19	101	3.0	131	6	7.36	7.25	41.7	10.7	31.6	0.284	3.56	0.25
6	236	18	94.0	3.6	120	7	7.27	7.19	35.9	10.2	30.0	0.215	3.29	0.25
7	195	18	77.9	3.6	101	7	7.23	7.19	33.9	10.3	27.9	0.231	3.57	0.26
8	194	17	80.4	3.4	101	6	7.03	6.98	24.6	9.36	20.4	0.416	3.08	0.24
9	163	16	65.7	3.4	88	7	7.09	7.05	30.7	10.4	23.6	0.309	2.77	0.26
10	189	16	77.9	3.2	90	6	7.16	7.17	33.3	10.4	28.2	0.360	2.99	0.24
11	218	19	92.6	3.8	107	7	7.62	7.45	41.5	11.8	34.3	0.594	3.43	0.22
12	262	18	118	3.1	121	7	7.7	7.5	44.2	11.8	36.7	0.508	4.04	0.22
平均值	231	18	94.8	3.4	113	7	7.3	7.2	37.5	10.5	29.3	0.412	3.68	0.23





污水化验2025年月平均报表

月份	COD _{Cr} (mg/L)		BOD ₅ (mg/L)		SS (mg/L)		PH (/)		TN (mg/L)		NH ₃ -N (mg/L)		TP (mg/L)	
	进水	出水	进水	出水	进水	出水	进水	出水	进水	出水	进水	出水	进水	出水
1	251	19	105	2.9	101	6	7.63	7.24	37.7	8.87	33.2	0.563	5.89	0.21
2	250	19	105	2.9	108	7	7.72	7.40	33.3	9.78	25.8	0.781	5.18	0.19
3	261	20	108	2.9	109	6	7.69	7.39	35.5	10.6	29.7	1.06	5.41	0.21
4	263	19	107	3.0	109	6	7.77	7.30	45.3	10.7	40.4	0.652	5.22	0.29
5	229	17	98.3	2.8	104	6	7.58	7.24	35.9	9.70	32.0	0.308	5.34	0.25
6	217	18	97.8	2.7	99	6	7.44	7.20	23.8	9.44	18.7	0.227	4.77	0.21
7	215	14	97.3	2.6	93	6	7.63	7.36	27.4	9.30	23.7	0.295	4.97	0.26
8	216	15	95.9	2.5	87	6	7.58	7.32	20.6	8.32	17.3	0.231	3.77	0.20
9	208	16	96.4	2.6	95	6	7.57	7.32	23.3	9.28	20.0	0.126	3.67	0.19
10	221	15	101	2.7	94	6	7.41	7.15	25.5	9.10	20.9	0.108	4.20	0.22
11	231	17	104	2.8	95	6	7.52	7.25	29.8	10.98	25.1	0.207	4.02	0.24
12	238	15	105	2.8	98	6	7.5	7.2	37.0	9.97	32.7	0.361	5.50	0.24
平均值	233	17	102	2.8	99	6	7.6	7.3	31.3	9.67	26.6	0.410	4.83	0.23

